Commissioners
Superintendent's Report

November 2, 2026

System Usage	2026	2025
October	6,673,004	8,409,817
Daily Average	215,258	271,284
Max Daily	383,671	503,179
Year to Date	77,596,421	78,610,370

1. Meter Reading is done. Billing is done. Maggi has done an excellent job correcting meter reading issues.
2. We spread wood chips around the back of Colby Point Pump Station completing the roof job. I'm still waiting to hear back about the warranty.
3. Stonkus Hydraulics completed the repairs on the Booster Station altitude valve and pilot system. Both are working as they should. This rebuild should be put on the pump and tank maintenance schedule every ten years.
4. I have been working on the Perley Rd and Reservoir Rd. Tony and Jon have completed all public hydrant winterizing. Tony will begin private hydrants this week. Jon has left work for the season and we look forward to his return in the spring.

Workload
Backflow Testing
Curb and Gate Repairs
Spillway @Pond

Respectfully Submitted,

Rob Thorp