Commissioners
Superintendent's Report

September 8, 2026

System Usage	2026	2025
August	10,436,554	11,491,661
Daily Average	336,663	370,698
Max Daily	513,899	522,046
Year to Date	62,245,776	60,291,661

1. A&D Instruments programmed our new frequency into the radios on the tank and at the pump station. Communications have been flawless.
2. The pump station roof is done. Jon and Tony raked around the building to prepare for bark mulch and Jon has been cleaning and painting the roof vents.
3. DN Tank is on the schedule for the 14th to begin repairs.
4. We have beaver activity at the pond. Tony and Jon will be taking the trapper up there tomorrow.
5. We had a callout at the booster station for high flow. The altitude valve used to fill the tank malfunctioned. We were able to shut it down manually and the next day, flushed the pilot control system. All seems to be functioning properly now.

Workload
Backflow Testing
Curb and Gate Repairs
Spillway @Pond

Respectfully Submitted,

Rob Thorp