

System Usage	2024	2023
December	6,000,000	5,410,000
Daily Average	193,548	174,516
Max Daily	370,000	280,000
Year to Date	82,137,000	77,190,000

1. All backflow testing for 2024 was completed on time.
2. We have been working with GZA conducting well monitoring and flow testing of each well. The monitoring equipment will be left in place for the next two to three weeks.
3. Quarterly reports are done and have been submitted to DES.
4. A&D Instruments installed a new chlorine analyzer at Colby Point Pump Station. The old chlorine analyzer was then placed at the Booster Station to facilitate the new chlorine system. Matt from A&D needs to come next to program in the high chlorine alarm in the SCADA system.
5. Dan Merzi delivered the bacteria test results for the Crocket Farm fire line. It passed. I informed them that they can move ahead.

Workload

Backflow Testing
Meter Change Outs
Service Line Inventory

Respectfully Submitted,

Rob Thorp