

System Usage	2025	2024
February	5,990,000	5,250,000
Daily Average	213,928	181,034
Max Daily	380,000	300,000
Year to Date	11,690,000	10,730,000

1. We need to make an adjustment to the base water rates.
2. The operator job posting and job description are ready for your review.
3. Jon completed his recertification for backflow testing.
4. We had a communication failure between the main tank and Colby Point Pump Station. I replaced a blown fuse however it was a couple of days before communication was restored. We will try to troubleshoot the exact cause when warmer weather returns.
5. Dan Tinkham from GZA had a crew on Colby Point last Thursday to pull their monitoring equipment. Dan advised that it would be about six to seven weeks before the drillers are here.
6. I spoke with Barrie Miller this morning about scheduling work on the lower three wells. He felt it would be best to do them in the fall.
7. Ken Butcher rekeyed, recoded the outside office door, and added a locking handle on the office closet.

**Workload**

Backflow Testing  
Service Line Inventory  
Reorganize Parts Room

Respectfully Submitted,

Rob Thorp