

| System Usage  | 2024      | 2023      |
|---------------|-----------|-----------|
| January       | 5,480,000 | 5,420,000 |
| Daily Average | 176,774   | 174,838   |
| Max Daily     | 300,000   | 300,000   |
| Year to Date  | 5,480,000 | 5,420,000 |

1. The hydrant at Hannaford Supermarket was not pumped out after the fire. Jon and Rod inspected it on Friday and found it to be frozen. I called the Fire Chief and informed him that we put the hydrant out of service and would thaw it on Monday. The hydrant was thawed without incident and no damage to the hydrant was noted.
2. I called Rod and Jon out on Sunday January 28<sup>th</sup> because the booster station was running and there were no active fire calls at the time. We discovered a leak in the fire service for the new highway garage. We shut the service down. On Thursday, we worked with the highway department to repair. I had Aaron Cartier from Sunapee assist.
3. Micah Senaca returned to repair the leak at 50 Icehouse Lane. He found an additional leak at a coupling closer to the house. He believes everything is repaired.
4. The illegal water hook up at 255 Newport Rd. (Concord Orthopedics) has been corrected.
5. The batteries in the backhoe were original and were failing. I replaced them last week.

**Workload**

Backflow Testing  
Meter Change Outs  
Shop Projects

Respectfully Submitted,

Rob Thorp