

Commissioners  
Superintendent's Report

March 4, 2024

System Usage	2024	2023
February	5,250,000	5,170,000
Daily Average	181,034	184,642
Max Daily	300,000	290,000
Year to Date	10,730,000	10,590,000

1. We had a water main break on Main St. by Springledge Farm last month. The call came in at 10:00 AM. We had the water back on and pressurized by 5:00 PM. New London DPW and Sunapee Water and Sewer assisted with the repair. New London Police and Fire assisted with traffic control.
2. Jon will be on vacation starting tomorrow and will be back at work next week.
3. I went to Sunapee last week and assisted them with a water main break for about five hours.
4. Rhonda submitted the backflow list to New Hampshire DES.
5. We have been performing typical shop work and equipment maintenance as well as rebuilding the spare chlorine pump.

**Workload**

Backflow Testing  
Meter Change Outs  
Shop Projects

*Summer / Lot Lines*

Respectfully Submitted,

  
Rob Thorp